

MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

| Subject Fire Lane Establishment Order for Thomas W. Pyle Middle School | Executive Order No. 92-17 | Subject Suffix |
|---|----------------------------------|------------------------------|
| Originating Department Montgomery County Department of Permitting Services | Department Number MCDPS 20-17 | Effective Date 05/30/2017 |

Fire Lane Establishment Order

Pursuant to Section 22 - 33, Montgomery County Code, 1971, as amended, you are hereby notified that a Fire Lane has been established as described in this order. You are hereby ordered to post fire lane signs and paint curbs/pavement (painting optional) as identified below. When signs and paint work (painting optional) have been completed, this order will authorize the enforcement of this Fire Lane by appropriate police and fire officials. Compliance with this order must be achieved within 30 days of receipt.

| LOCATION: | 6311 | <u>Wilson La.</u> | | | |
|-----------|------|-------------------|--|--|--|
| | | | | | |
| | | | | | |
| | | | | | |

All areas where indicated by signs and paint.

SIGNS - - (See attached diagram for location of sign placement)

1

\$250 FINE

Signs must be posted so that it is not possible to park a vehicle without being in sight of a sign. Signs may be no further

FIRE LANE


apart than 100 feet

(Red letters on white background)

 \square PAINT - - (See attached diagram if painting).


Paint must be traffic yellow with lines of sufficient width to be readily identifiable/ readable by motor vehicle operators.

Fire Marshal, Montgomery County Department of Permitting Services



VICINITY MAP

SCALE: 1"=1000'



SIGN PLACEMENT DIAGRAM







FIRE LANE SIGNS

GENERAL NOTES:


- 1. SIGNS TO BE CONSISTENT WITH THE MONTGOMERY COUNTY FIRE AND RESCUE (MCFR) GUIDELINES
- 2. FIRE LANE SIGNS TO BE 12" WIDE BY 18" HIGH



Engineering a Sustainable Future Nobis Engineering, Inc. 20410 Century Blvd Suite 230 Germantown, MD 20874 T(301) 528-2010 www.nobiseng.com Client - Focused, Employee - Owned THOMAS W. PYLE MIDDLE SCHOOL
6301 WILSON LANE
BETHESDA, MD 20817
FIRE LANE ACCESS PLAN

 JOB NO.:
 86980.71
 SHEET NO:

 SCALE:
 1" = 1000'
 DATE: MAY 2017
 1 OF 2



FIRE LANE PLAN
1"=150'

LEGEND

• FIRE LANE SIGN (TYP)



Engineering a Sustainable Future Nobis Engineering, Inc. 20410 Century Blvd Suite 230 Germantown, MD 20874 T(301) 528-2010 www.nobiseng.com Client - Focused, Employee - Owned THOMAS W. PYLE MIDDLE SCHOOL 6301 WILSON LANE BETHESDA, MD 20817 FIRE LANE ACCESS PLAN

| JOB NO.: 86980.71 | | SHEET NO: |
|-------------------|----------------|-----------|
| SCALE: 1" = 150' | DATE: MAY 2017 | 2 OF 2 |